

Product Safety Recall



Electresafe® Powercentre with RCBO Protection

Cat. REPC410, REPC415, REPC410USB & REPC410USBAC

Instruction Manual



REPC410USBAC

1 Instructions for use

- Step 1.** Uncoil lead fully from around base.
- Step 2.** Plug your Powercentre into a fixed powerpoint and turn the powerpoint on. Do not plug into an extension lead.
- Step 3.** Lift clear protective cover on side and ensure the RCBO toggle is ON.
- Step 4.** **TEST THE RCBO BEFORE EACH USE** by pressing the Test Button. The RCBO toggle should immediately trip to the OFF position. If the RCBO fails to trip OFF, after the RCBO Test Button is pressed, do not use as the RCBO may be faulty. Return to HPM for repair.
- Step 5.** **RESET THE RCBO** by simply switching the RCBO toggle to ON.

Your Powercentre is now ready for use.

Simply plug in your tools and use as normal.

The RCBO can also trip through overcurrent. If too many high current tools are plugged into your Powercentre the RCBO will automatically

3 Specifications

Voltage:	230-240V a.c. 50Hz
Max Load:	2400W 10A and 3600W 15A
Lead:	1.0mm ² flexible heavy duty – 1.8m (10A) 1.5mm ² flexible heavy duty – 1.8m (15A)
Plug:	Clear, fully moulded
Rated Residual Current:	30mA
Typical Trip Time:	30ms
IP Rating:	IP33
USB output:	5V d.c., 2 x 2.4A (REPC410USB model only) Type-D port max output: 5V d.c., 3A Type-A port max output: 5V d.c., 2.4A Total max output: 5V d.c., 5A (REPC410USBAC model only)
Classification:	Type 2 FS and Class H rating. Impact resistant material

HPM Electresafe Powercentre Cat. REPC410, REPC415, REPC410USB, REPC410UBAC

ATTENTION CUSTOMERS: Legrand New Zealand Limited is recalling the above product sold between January 2018 and December 2024. Date codes containing 18Wxx to 24Wxx where “Type FS” is listed on the product label as shown above.

DEFECT: The product is labelled “Type FS” and the instruction manual lists the FS feature when the product did not have this feature.

HAZARD: The product, due to the incorrect label, is deemed unsafe under the Electricity (Safety) Regulations 2010.

CONSEQUENCES: Apart from the incorrect label, there is no manufacturing or functional issue with the product, and it is compliant to all applicable standards when used as recommended.

WHAT TO DO: The affected product must be relabelled. Legrand will provide a remedy kit including a replacement label with the correct product information and an instruction manual detailing the updated specifications. For further details contact Legrand New Zealand Customer Service Centre.

Contact details:

Customer Service Centre: phone **0800 476 009** or email nz.sales@legrand.co.nz and include “Recall” in the subject line. Physical address: 106/124 Target Road, Glenfield, Auckland, New Zealand.

Visit www.hpm.co.nz/help-centre for further details.

NO OTHER HPM PRODUCTS ARE AFFECTED

New Zealand Importer/Distributor

Legrand New Zealand Limited

Issued: 31 January 2025